




2007


CA MECHANICAL CODE
310.0, 802.8.4 & 802.9




A—PROHIBITED BY U.P.C. SECTION 311.4




B—PROHIBITED BY U.P.C. SECTION 311.4




C—ACCEPTABLE




D—ACCEPTABLE



E—ACCEPTABLE



F—ACCEPTABLE WITH STRAINER ONLY. NO PLUG OR STOPPER



G—PROHIBITED BY U.P.C. SECTION 311.4

TRAPS TO BE INSTALLED WHEN REQUIRED BY MANUFACTURER'S INSTALLATION INSTRUCTIONS AND U.P.C. SECTION 803.

NOTE: "VTR" MEANS (PLUMBING) VENT THROUGH ROOF.

CONDENSATE DRAIN TERMINATIONS